



- KEY**
- 6A **Lantern:** Philips Residium FGS224/Libra-PT
Tilt: 5°
Column: 6m Stepped Tubular Steel
Lamp: 36W PL-L
Control: Telensa
 - Quantity 4
 - ⊕ Existing Non DTC Lighting Column To Be Removed For Recycling
 Quantity 4
 - ⊕ Existing Non DTC Lighting Column to be Removed and not Replaced as Annex A Agreed with CCC
 Quantity 2
 - ⊖ Disconnection of DNO Supply
 - T Transfer of DNO Supply
 - 🌳 Tree
 - 🌿 Hedge

Design Notes

1. 1-4-1 (Residential) Lighting Design

All lighting column positions marked on site are indicative only

Notes

DIMMING REGIME
 • RESIDENTIAL DIM TO 60% BETWEEN 22:00 & 06:00

WARNING - THERE ARE BURIED SERVICES WITHIN THIS SCHEME. REFER TO DIG PACK PRIOR TO REMOVAL / INSTALL AND ENSURE DIG PACK CONTAINS ALL THE INFORMATION

COPYRIGHT RESERVED, BALFOUR BEATTY LIVING PLACES IS THE OWNER OF THE COPYRIGHT SUBSISTING IN THESE DRAWINGS, PLANS, DESIGNS AND SPECIFICATIONS. THEY MUST NOT BE USED, REPRODUCED OR COPIED, IN WHOLE OR IN PART, NOR MAY THE INFORMATION, IDEAS AND CONCEPTS THEREIN CONTAINED (WHICH ARE CONFIDENTIAL TO BALFOUR BEATTY LIVING PLACES) BE DISCLOSED TO ANY PERSON WITHOUT THE PRIOR SPECIFIC WRITTEN CONSENT OF BALFOUR BEATTY LIVING PLACES.



Designer: PT Date of issue: 24/10/14

Checked: DM Authorised: NB Sheet Size: A3 Scale: 1:500 @ A3

Issue: PRELIMINARY Revision: ORIG.

Drawing no.: 7200-1425-V3

Scheme Name and Ward: Cambridge 1425, Cambridge City

Streets on drawing: Stansgate Road, Milestone 7
 Sheet 1 of 1

Schedule Of Existing Columns									
Stansgate Ave	Column		Supply Point	Service Alteration Type	Attachment		Notes	Location	Lamp/Types
	Number	Set back			Type	Alteration Type			
Lighting Column	CC1	BOP	DNO	Transfer to L1SGJ				o/s no. 1	35W SOX
	CC2	BOP	DNO	Disconnect DNO Supply	N Watch	Transfer to L1SGJ		o/s no. 7	
	CC3	Verge	DNO	Transfer to L2SGJ	N Watch	Transfer to L2SGJ		opp. No. 17	
	CC4	BOP	DNO	Transfer to L3SGJ	N Watch	Transfer to L3SGJ		s/o no. 25	
	CC5	BOP	DNO	Disconnect DNO Supply				o/s no. 31	
	CC6	BOP	DNO	Transfer to L4SGJ	N Watch	Transfer to L4SGJ		o/s no. 24	

Schedule Of Proposed Columns									
Stansgate Ave	Column		Supply Point	Service Alteration Type	Attachment		Notes	Location	Lamp/Types
	Number	Set back			Type	Alteration Type			
Lighting Column	L1SGJ	BOP	DNO	Transfer from CC1				o/s no. 1	36W PL-L
	L2SGJ	Verge	DNO	Transfer from CC3	N Watch	Transfer from CC3		opp. No. 17	
	L3SGJ	BOP	DNO	Transfer from CC4	N Watch	Transfer from CC4		s/o no. 25	
	L4SGJ	BOP	DNO	Transfer from CC6	N Watch	Transfer from CC6		o/s no. 24	